



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

## NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786)315-2590 F (786) 315-2599

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

GAF

1 Campus Drive  
Parsippany, NJ 07054

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION:** EverGuard® PVC XK Fleeceback, EverGuard® PVC XK and EverGuard® PVC Smooth Single Ply Roof Systems over Structural Concrete Decks.

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 13-0603.12 and consists of pages 1 through 17.  
The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 15-0203.13  
Expiration Date: 03/28/18  
Approval Date: 04/30/15  
Page 1 of 17

## ROOFING SYSTEM APPROVAL

**Category:** Roofing  
**Sub-Category:** Single Ply Roofing  
**Material:** PVC  
**Deck Type:** Concrete  
**Maximum Design Pressure:** -502.5 psf

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
EverGuard® PVC XK Fleeceback	60 mil thick 10' x 90' 76" x 90'	D4434	Polyester felt-backed PVC KEE based membrane for application in hot asphalt or adhesive.
EverGuard® PVC Smooth	80 mil thick 10' x 75' 76" x 75'	D4434	Polyester single ply PVC membrane for mechanically attached or adhered applications.
EverGuard® PVC XK	50 mil thick 10' x 100' 5' x 100'	D4434	Polyester single ply PVC KEE based membrane for mechanically attached or adhered applications.
EverGuard® PVC XK	60 mil thick 10' x 80' 5' x 80'	D4434	Polyester single ply PVC KEE based membrane for mechanically attached or adhered applications.
EverGuard® PVC XK	80 mil thick 10' x 65' 5' x 65'	D4434	Polyester single ply PVC KEE based membrane for mechanically attached or adhered applications.
EverGuard® PVC XK	60 mil thick 10' x 90' 76" x 90'	D4434	Polyester single ply PVC KEE based membrane for mechanically attached or adhered applications.
EverGuard® PVC XK	80 mil thick 10' x 75' 76" x 75'	D4434	Polyester single ply PVC KEE based membrane for mechanically attached or adhered applications.
LRF Adhesive M	Dual component cylinders	proprietary	A two component, one-step, all-purpose foamable adhesive.
LRF Adhesive O	Dual component cylinders	proprietary	A two component, one-step, membrane foamable adhesive.
EverGuard® #2331 Bonding Adhesive	5 gallons	Proprietary	Adhesive for fully adhered systems and membrane flashing.
EverGuard® WB 181 Bonding Adhesive	5 gallons	Proprietary	A water based adhesive for PVC and TPO based membranes.
Matrix #307 Premium Asphalt Primer	3, 5, 55 gallons	ASTM D 41	Asphalt concrete primer used to promote adhesion of asphalt.
EverGuard® PVC Round Stack	Various	proprietary	PVC membrane molded to wrap around round roof structures.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
EverGuard® PVC Outside Corner	6x6	proprietary	Outside corner of base and curb flashing.
EverGuard® PVC Corner Curb Flashing	Various	proprietary	Corners are fabricated from reinforced PVC membrane.
EverGuard® PVC Square Tube Wrap	Various	proprietary	PVC membrane molded to wrap around square roof structures.
EverGuard® PVC Inside Corner	6 x 6 x 5-1/4	proprietary	Inside corner of base and curb flashing.
EverGuard® PVC Coated Metal	Various	proprietary	Un-reinforced membrane laminated to galvanized sheet metal.
Topcoat® Elastomeric Roofing Membrane	1, 5 or 55gal.	ASTM D6083	An acrylic, water based elastomeric membrane system used to protect various types of roofing surfaces

**APPROVED INSULATIONS:**

**TABLE 2**

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
EnergyGuard™ Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ Tapered Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ RA Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ RA Tapered Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ RH Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ RH Tapered Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ RM Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ RN Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ RN Tapered Polyiso Insulation	Polyisocyanurate foam insulation	GAF
Securock® Gypsum-Fiber Roof Board	Gypsum board	US Gypsum Corp.



**APPROVED FASTENERS:**

**TABLE 3**

<b>Fastener Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Dimensions</b>	<b>Manufacturer (With Current NOA)</b>
1.	N/A	N/A	N/A	N/A

**EVIDENCE SUBMITTED:**

<b><u>Test Agency/Identifier</u></b>	<b><u>Report</u></b>	<b><u>Test Name</u></b>	<b><u>Date</u></b>
FM Approvals	3044914	4470	06/18/12
	3041769	4470	05/26/11
Trinity-ERD	F35940.12.11-R2	ASTM D4434	02/27/12
	F35940.10.11-2-R2	ASTM D4434	02/27/12
Atlantic & Caribbean Roof Consulting, LLC	11-058	TAS 114-D	10/03/11
	11-059	TAS 114-D	10/04/11
	11-060	TAS 114-D	10/05/11
	12-005	TAS 114-D	04/09/12
	12-006	TAS 114-D	04/09/12
	12-007	TAS 114-D	04/10/12
	12-020	TAS 114-D	05/08/12
12-021	TAS 114-D	04/26/12	
PRI Construction Materials Technologies, LLC	GAF-082-02-01	ASTM D6083	05/26/06



**APPROVED ASSEMBLIES:**

**Membrane Type:** Single Ply, PVC

**Deck Type 3I:** Concrete Deck, Insulated

**Deck Description:** 3,000 psi structural concrete deck.

**System Type A(1):** Insulation is adhered to the roof deck, membrane is adhered to the insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of the following insulations :

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
Securock <sup>®</sup> Gypsum-Fiber Roof Board Minimum: 1/4" Thick	N/A	N/A

**Note: Securock<sup>®</sup> Gypsum-Fiber Roof Board is adhered to deck with OlyBond 500<sup>®</sup> or OlyBond 500<sup>®</sup> Green in 1" wide ribbons spaced 12" o.c. or adhered with LRF Adhesive M applied in 1" wide ribbons spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** One ply of EverGuard<sup>®</sup> PVC XK Fleeceback partially adhered to the insulation with LRF Adhesive M applied in 1" wide ribbons spaced 6" o.c. The laps are heat welded a minimum of 1-1/2" width for automatic machine welding. Weld width shall be minimum 2" width for hand welding. The membrane is then rolled with a water filled roller weighing a minimum of 250 lbs.

**Surfacing:** (Optional) Topcoat<sup>®</sup> Elastomeric Roofing Membrane applied per manufacturer's instructions.

**Maximum Design Pressure:** -500 psf (See General Limitation #9.)



**Membrane Type:** Single Ply, PVC

**Deck Type 3I:** Concrete Deck, Insulated

**Deck Description:** 3,000 psi structural concrete deck.

**System Type A(2):** Insulation is adhered to the roof deck, membrane is adhered to the insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of the following insulations :

<b>Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>EnergyGuard™ RN Polyiso Insulation Minimum: 1" Thick</b>	N/A	N/A

**Note: Insulation is adhered in OlyBond 500®, OlyBond 500® Green or LRF M Adhesive in 1" wide ribbons spaced 12" o.c. to the concrete deck. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** One ply of EverGuard® PVC XK Fleeceback partially adhered to the insulation with LRF Adhesive M applied in 1" wide ribbons spaced 6" o.c. The laps are heat welded a minimum of 1-1/2" width for automatic machine welding. Weld width shall be minimum 2" width for hand welding. The membrane is then rolled with a water filled roller weighing a minimum of 250 lbs.

**Surfacing:** (Optional) Topcoat® Elastomeric Roofing Membrane applied per manufacturer's instructions.

**Maximum Design Pressure:** -440 psf (See General Limitation #9.)



**Membrane Type:** Single Ply, PVC

**Deck Type 3I:** Concrete Deck, Insulated

**Deck Description:** 3,000 psi structural concrete deck.

**System Type A(3):** Insulation is adhered to the roof deck, membrane is adhered to the insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of the following insulations :

<b>Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>EnergyGuard™ RH Polyiso Insulation Minimum: 1" Thick</b>	N/A	N/A

**Note: Insulation is adhered in Olybond 500® or Olybond 500® Green in 1" wide ribbons spaced 12" o.c. to the concrete deck. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** One ply of EverGuard® PVC XK Fleeceback partially adhered to the insulation with LRF Adhesive O applied in 1" wide ribbons spaced 6" o.c. The laps are heat welded a minimum of 1-1/2" width for automatic machine welding. Weld width shall be minimum 2" width for hand welding. The membrane is then rolled with a water filled roller weighing a minimum of 250 lbs.

**Surfacing:** (Optional) Topcoat® Elastomeric Roofing Membrane applied per manufacturer's instructions.

**Maximum Design Pressure:** -467.5 psf (See General Limitation #9.)



**Membrane Type:** Single Ply, PVC

**Deck Type 3I:** Concrete Deck, Insulated

**Deck Description:** 3,000 psi structural concrete deck.

**System Type A(4):** Insulation is adhered to the roof deck, membrane is adhered to the insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of the following insulations :

<b>Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>EnergyGuard™ RH Polyiso Insulation Minimum: 1" Thick</b>	N/A	N/A

**Note: Insulation is adhered to the concrete deck in LRF Adhesive M applied in 1" wide ribbons spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** One ply of EverGuard® PVC XK Fleeceback partially adhered to the insulation with LRF Adhesive M applied in 1" wide ribbons spaced 6" o.c. The laps are heat welded a minimum of 1-1/2" width for automatic machine welding. Weld width shall be minimum 2" width for hand welding. The membrane is then rolled with a water filled roller weighing a minimum of 250 lbs.

**Surfacing:** (Optional) Topcoat® Elastomeric Roofing Membrane applied per manufacturer's instructions.

**Maximum Design Pressure:** -345 psf (See General Limitation #9.)



**Membrane Type:** Single Ply, PVC

**Deck Type 3I:** Concrete Deck, Insulated

**Deck Description:** 3,000 psi structural concrete deck.

**System Type A(5):** Insulation is adhered to the roof deck, membrane is adhered to the insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of the following insulations :

<b>Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>EnergyGuard™ RH Polyiso Insulation Minimum: 1" Thick</b>	N/A	N/A

**Note: Insulation is adhered in asphalt applied at 20-25 lbs./sq. to the concrete deck previously primed with Matrix #307 Premium Asphalt Primer. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** One ply of EverGuard® PVC XK Fleeceback adhered to the insulation in asphalt applied at 20-25 lbs./sq. The laps are heat welded a minimum of 1-1/2" width for automatic machine welding. Weld width shall be minimum 2" width for hand welding. The membrane is then rolled with a water filled roller weighing a minimum of 250 lbs.

**Surfacing:** (Optional) Topcoat® Elastomeric Roofing Membrane applied per manufacturer's instructions.

**Maximum Design Pressure:** -490 psf (See General Limitation #9.)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete Deck, Insulated  
**Deck Description:** 3,000 psi structural concrete deck.

**System Type A(6):** Insulation is adhered to the roof deck, membrane is adhered to the insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of the following insulations :

<b>Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>EnergyGuard™ Polyiso Insulation, EnergyGuard™ Tapered Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RA Tapered Polyiso Insulation, EnergyGuard™ RM Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation, EnergyGuard™ RN Tapered Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RH Tapered Polyiso Insulation</b>		
<b>Minimum: 1" Thick</b>	<b>N/A</b>	<b>N/A</b>

**Note: All Insulation may be adhered with OlyBond® 500 or OlyBond 500® Green applied in 0.75 – 1 inch ribbons spaced 12 inches o.c.**

**Or**

**EnergyGuard RA, RN, RH Polyiso Insulation may also be adhered with LRF Adhesive M applied in 1" wide ribbons spaced 12" o.c.**

**Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** One ply of EverGuard® PVC Smooth or EverGuard® PVC XK adhered to the insulation with EverGuard® WB 181 Bonding Adhesive applied at a total rate of 0.84 gal./sq. Apply the adhesive to the underside of the membrane and to the insulation. The laps are heat welded a minimum of 1-1/2" width for automatic machine welding. Weld width shall be minimum 2" width for hand welding. The membrane is then rolled with a water filled roller weighing a minimum of 250 lbs.

**Surfacing:** (Optional) Topcoat® Elastomeric Roofing Membrane applied per manufacturer's instructions.

**Maximum Design**

**Pressure:** -90 psf (See General Limitation #9.)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete Deck, Insulated  
**Deck Description:** 3,000 psi structural concrete deck.

**System Type A(7):** Insulation is adhered to the roof deck, membrane is adhered to the insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of the following insulations :

<b>Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Securock<sup>®</sup> Gypsum-Fiber Roof Board Minimum: 1/4" Thick</b>	N/A	N/A

**Note: Insulation is adhered with OlyBond<sup>®</sup> 500 or OlyBond 500<sup>®</sup> Green applied in 0.75 – 1 inch ribbons spaced 12 inches o.c. or adhered with LRF Adhesive M applied in 1" wide ribbons spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** One ply of EverGuard<sup>®</sup> PVC Smooth adhered to the insulation with EverGuard<sup>®</sup> WB 181 Bonding Adhesive applied at a total rate of 0.84 gal./sq. Apply the adhesive to the underside of the membrane and to the insulation. The laps are heat welded a minimum of 1-1/2" width for automatic machine welding. Weld width shall be minimum 2" width for hand welding. The membrane is then rolled with a water filled roller weighing a minimum of 250 lbs.

**Surfacing:** (Optional) Topcoat<sup>®</sup> Elastomeric Roofing Membrane applied per manufacturer's instructions.

**Maximum Design Pressure:** -67.5 psf (See General Limitation #9.)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete Deck, Insulated  
**Deck Description:** 3,000 psi structural concrete deck.

**System Type A(8):** Insulation is adhered to the roof deck, membrane is adhered to the insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**All General and System Limitations apply.**

One or more layers of the following insulations :

<b>Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>EnergyGuard™ Polyiso Insulation, EnergyGuard™ Tapered Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation, EnergyGuard™ RA Tapered Polyiso Insulation, EnergyGuard™ RM Polyiso Insulation, EnergyGuard™ RN Polyiso Insulation, EnergyGuard™ RN Tapered Polyiso Insulation, EnergyGuard™ RH Polyiso Insulation, EnergyGuard™ RH Tapered Polyiso Insulation Minimum: 1" Thick</b>	<b>N/A</b>	<b>N/A</b>

**Note: All Insulation may be adhered with OlyBond® 500 or OlyBond 500® Green applied in 0.75 – 1 inch ribbons spaced 12 inches o.c.**

**Or**

**EnergyGuard RA, RN, RH Polyiso Insulation may also be adhered with LRF Adhesive M applied in 1" wide ribbons spaced 12" o.c.**

**Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** One ply of EverGuard® PVC Smooth or EverGuard® PVC XK adhered to the insulation with EverGuard® #2331 Bonding Adhesive applied at a total rate of 1.67 gal./sq. Apply the adhesive to the underside of the membrane and to the insulation. The laps are heat welded a minimum of 1-1/2" width for automatic machine welding. Weld width shall be minimum 2" width for hand welding. The membrane is then rolled with a water filled roller weighing a minimum of 250 lbs.

**Surfacing:** (Optional) Topcoat® Elastomeric Roofing Membrane applied per manufacturer's instructions.

**Maximum Design**

**Pressure:** -247.5 psf (See General Limitation #9.)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete Deck, Insulated  
**Deck Description:** 3,000 psi structural concrete deck.

**System Type A(9):** Insulation is adhered to the roof deck, membrane is adhered to the insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of the following insulations :

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Securock<sup>®</sup> Gypsum-Fiber Roof Board Minimum: 1/4" Thick</b>	N/A	N/A

**Note: Insulation is adhered with OlyBond<sup>®</sup> 500 or OlyBond 500<sup>®</sup> Green applied in 0.75 – 1 inch ribbons spaced 12 inches o.c. or adhered with LRF Adhesive M applied in 1" wide ribbons spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** One ply of EverGuard<sup>®</sup> PVC Smooth or EverGuard<sup>®</sup> PVC XK adhered to the insulation with EverGuard<sup>®</sup> #2331 Bonding Adhesive applied at a total rate of 1.67 gal./sq. Apply the adhesive to the underside of the membrane and to the insulation. The laps are heat welded a minimum of 1-1/2" width for automatic machine welding. Weld width shall be minimum 2" width for hand welding. The membrane is then rolled with a water filled roller weighing a minimum of 250 lbs.

**Surfacing:** (Optional) Topcoat<sup>®</sup> Elastomeric Roofing Membrane applied per manufacturer's instructions.

**Maximum Design Pressure:** -202.5 psf (See General Limitation #9.)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3:** Concrete Deck, Non- Insulated  
**Deck Description:** 3,000 psi structural concrete deck.  
**System Type F(1):** Membrane is adhered to roof deck.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** One ply of EverGuard® PVC XK Fleeceback partially adhered to the deck with LRF Adhesive O or LRF Adhesive M applied in 1” wide ribbons spaced 6” o.c. The laps are heat welded a minimum of 1-1/2” width for automatic machine welding. Weld width shall be minimum 2” width for hand welding. The membrane is then rolled with a water filled roller weighing a minimum of 250 lbs.

**Surfacing:** (Optional) Topcoat® Elastomeric Roofing Membrane applied per manufacturer’s instructions.

**Maximum Design Pressure:** -502.5 psf (See General Limitation #9.)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3:** Concrete Deck, Non- Insulated  
**Deck Description:** 3,000 psi structural concrete deck.  
**System Type F(2):** Membrane is adhered to primed roof deck.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** One ply of EverGuard® PVC XK Fleeceback is adhered to the primed deck in asphalt applied at a rate of 20-25 lbs./sq. The deck is primed with Matrix™ #307 Premium Asphalt Primer. Laps are heat welded a minimum of 1-1/2” width for automatic machine welding. Weld width shall be minimum 2” width for hand welding. The membrane is then rolled with a water filled roller weighing a minimum of 250 lbs.

**Surfacing:** (Optional) Topcoat® Elastomeric Roofing Membrane applied per manufacturer’s instructions.

**Maximum Design Pressure:** -502.5 psf (See General Limitation #9.)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3:** Concrete Deck, Non- Insulated  
**Deck Description:** 3,000 psi structural concrete deck.  
**System Type F(3):** Membrane is adhered to roof deck.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** One ply of EverGuard® PVC XK Fleeceback is adhered to the deck with EverGuard® WB 181 Bonding Adhesive applied at a total rate of 0.84 gal./sq. Laps are heat welded a minimum of 1-1/2” width for automatic machine welding. Weld width shall be minimum 2” width for hand welding. The membrane is then rolled with a water filled roller weighing a minimum of 250 lbs.

**Surfacing:** (Optional) Topcoat® Elastomeric Roofing Membrane applied per manufacturer’s instructions.

**Maximum Design Pressure:** -90 psf (See General Limitation #9.)



## CONCRETE DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117 and/or RAS 137, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.

## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.  
**Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant  
**(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners).  
**(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

**END OF THIS ACCEPTANCE**



NOA No.: 15-0203.13  
Expiration Date: 03/28/18  
Approval Date: 04/30/15  
Page 17 of 17